

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 118198
Permit No. _____
Basin 045

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69517 ✓

1 OWNER LLOYD CARSON ADDRESS AT WELL LOCATION 83 FOOTHILL DR
MAILING ADDRESS P.O. BOX 281412
LAMOILLE, NV 89828 Subdivision Name: RURAL LANDS County: ELKO

2 LOCATION SE 1/4 SW 1/4 Sec 28 T 33N N/S R 58 E Latitude UTM E 11T 0631470 NAD 27
PERMIT/WAIVER No. 007-080-0AC Longitude N 4507393 NAD 83/WGS 84
Issued by Water Resources Parcel No.

3 TYPE OF WELL Domestic Irrigation Test Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? YES
If yes, what is replacement well NOI? 69518
Is there an existing well log? YES
If yes, what is NDWR well log #? 43069

4 EXISTING WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 338 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1.5	280
5.563	14.63	.258	170	338

Existing Perforations:

Type of perforation	MILL SLOT
Size of perforation	3/16" X 3"
From <u>260</u> feet to <u>280</u> feet	
From <u>(5.5") 190</u> feet to <u>338</u> feet	
From <u> </u> feet to <u> </u> feet	
From <u> </u> feet to <u> </u> feet	

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: HOLTZ
From 180 feet to 260 feet Number of perfs per linear foot 8
From feet to feet Number of perfs per linear foot
From feet to feet Number of perfs per linear foot
From feet to feet Number of perfs per linear foot
From feet to feet Number of perfs per linear foot
From feet to feet Number of perfs per linear foot

5 WATER LEVEL
Static water level 282 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 51 °F Quality GOOD

8 WELL PLUGGING MATERIALS

From	feet to	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From <u>50</u>	feet to <u>440</u>	<u>SUPER PLUG</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From <u>30</u>	feet to <u>50</u>	<u>3/8" CHIPS</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
From <u>4</u>	feet to <u>30</u>	<u>NEAT CEMENT</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
From <u> </u>	feet to <u> </u>	<u> </u>	<input type="checkbox"/>	<input type="checkbox"/>
From <u> </u>	feet to <u> </u>	<u> </u>	<input type="checkbox"/>	<input type="checkbox"/>
From <u> </u>	feet to <u> </u>	<u> </u>	<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
5.5" LINER CASING COULDN'T BE PULLED, CLEANED HOLE TO BOTTOM AND PUMPED SUPER PLUG UP TO SURFACE.

Neat Cement Fluid Weight 16 lbs/gal
Bentonite Grout 20 % bentonite
Date Started 10-Dec-12
Date Completed 10-Dec-12

BLEW SUPER PLUG OUT TO 50', INSTALLED 3/8" CHIPS UP TO 30' AND THEN NEAT CEMENT UP TO 4'.

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING INC Contractor
Address P. O. BOX 850 Contractor
ELKO, NV 89803
Nevada contractor's license number 020582
issued by the State Contractor's Board
Nevada driller's license number issued by the 1653
Division of Water Resources, the on-site driller
Signed [Signature]
Date 26-Dec-12

RECEIVED
2013 JAN 16 AM 10:33
STATE ENGINEERS OFFICE
NAD 27 40.708870°N
115.443669°W