STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118294
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67101

1. OWNER REGIONAL TRANSPORTATION COMMISSION
MAILING ADDRESS 1105 TERMINAL WAY, STE. 108
RENO, NV. 89502

ADDRESS AT WELL LOCATION ROSEWOOD LAKES GOLF COURSE
6800 PEMBROKE DR., RENO, NV., 89523
Subdivision Name: County: Washoe

2. LOCATION NW ¼ SW ¼ Sec 22 T 19N N/S R 20 E
PERMIT/WAIVER No. M/O-1874 (Issued by Water Resources) 021-160-44 Parcel No.

Latitude 39.49553°
Longitude -119.73093°
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND	YES	0	12	12
WELL KNOWN AS B-58 ON				
WAIVER PAPER WORK BUT				
WAS CHANGED IN THE				
FIELD TO B-4				
Plugged By Well				
Log 125158				

Date started: 27-Feb, 20 13
Date completed: 27-Feb, 20 13

9. WELL CONSTRUCTION
Depth Drilled 12 Feet Depth Cased 12 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	12	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	12

Perforations:
Type of perforation FACTORY SLOT
Size of perforation .020
From 7 feet to 12 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0 to 4	☐ Pumped	☒ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 6 to 12 ☐ Pumped ☒ Poured
Type: 10/20 SILICA SAND
Bentonite Chips: ☒ Yes ☐ No 4 to 6 ☐ Pumped ☒ Poured
Type: 3/8 BENTONITE CHIPS

7. Water Level
Static water level: 6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: <85 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NAD27	39.495633°N	
	119.731963°W	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HAZ-TECH DRILLING, INC. (Contractor)
Address PO BOX 940 (Contractor)
MERIDIAN, ID. 83680
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2137
Signed (By driller performing actual drilling on site or contractor)
Date 3-19-13

RECEIVED 2013 APR 1 PM 1:21 STATE ENGINEER'S OFFICE

(Rev. 03-09)

USE ADDITIONAL SHEETS IF NECESSARY