STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118309
Permit No.
Basin 056

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69260 ✓

1. OWNER Carl Brooks
MAILING ADDRESS HC 61 Box 6190
Austin, NV 89310

ADDRESS AT WELL LOCATION Upper Reese River Valley
Austin, NV 89310
Subdivision Name: County: Lander

2. LOCATION NE ¼ SW ¼ Sec 28 T 15N N/S R 41 E
PERMIT/WAIVER No.
Issued by Water Resources Parcel No.

Latitude 39.13373 N
Longitude -117.37601 W
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Rock		0	15	15
Rock		15	26	11
Rock Gravel		26	62	36
Clay		62	68	6
Rock Gravel	XX	68	120	52

RECEIVED
2012 SEP 20 AM 11:41
STATE ENGINEERS OFFICE

Date started: 27-Aug , 20 12
Date completed: 28-Aug , 20 12

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	105
6.625	12.92	.188	105	120

Perforations:
Type of perforation Mill cut
Size of perforation 0.1875
From 105 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 105 to 0 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 105 to 120 ☐ Pumped ☒ Poured
Type: 3/8" well gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NAD27	39.13373 °N		
	117.37601 °W		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1265
Contractor
Fallon, NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed [signature]
By driller performing actual drilling on site or contractor
Date 8/5/2012

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY