STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118362
Permit No.
Basin No. 01

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70246
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Mark Hyde
MAILING ADDRESS 9655 Pioneer Way
Fallon, Nv 89406

DETAILED ADDRESS AT WELL LOCATION 3015 Schindler Rd
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION NE ¼ NE ¼ 15 Sec 18N N/S 28 E
PERMIT/WAIVER NO. *Issued by Water Resources* 006-451-17 *Current Parcel No.*

Latitude 39.43076 N UTM E ☐ NAD 27
Longitude 118.81954 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Sand			0	5	5
Brown Clay			5	18	13
Coarse Sand			18	36	18
Black Clay			36	68	32
Black sand			68	73	5
Black Clay w/ Black			73	96	23
sand streaks					
Black Clay			96	116	20
Med Brown Gravel		X	116	121	5
Blue Clay		X	121	122	1

NAD27
39.4308420 N
118.8185540 W

Date started: 23-Sep, 20 13
Date completed: 24-Sep, 20 13

9. WELL CONSTRUCTION
Depth Drilled: 122 Feet Depth Cased: 122 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	122	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	20
6.625	4	.316	20	122

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 0.125
From 120 Feet To 122 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0 to 100			
☒ Neat Cement	0 to 100	☒ Pumped	☐ Poured	
☐ Cement Grout	to	☐ Pumped	☐ Poured	
☐ Concrete Grout	to	☐ Pumped	☐ Poured	
☐ Bentonite Chips	to	☐ Pumped	☐ Poured	
☐ Bentonite Grout	to	☐ Pumped	☐ Poured	
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	100 to 122	☐ Pumped	☒ Poured	
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured	
☐ Other, explain:	to	☐ Pumped	☐ Poured	

7. WATER QUALITIES
Static water level: 19 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. *Contractor*
Address P.O. Box 1265 Fallon, NV 89407 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2285
Signed: *By driller performing actual drilling on site or contractor*
Date: 10/1/2013

RECEIVED 2013 OCT 23 AM 11:08 STATE ENGINEER'S OFFICE

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY