

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 118507
Permit No. _____
Basin 105

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 69881

1 OWNER A&A Construction
MAILING ADDRESS P.O. Box 995
Minden, NV, 89423

ADDRESS AT WELL LOCATION Near intersection of Lasso Lane and
Heybourne Road in Gardnerville, NV.
Subdivision Name: The Ranch @ Gardnerville County: Douglas

2 LOCATION SW 1/4 NW 1/4 Sec 33 T 13N N/S R 20 E
PERMIT/WAIVER No. _____
Issued by Water Resources Parcel No.

Latitude 38 56.864 N UTM E NAD 27
Longitude 119 44.960 W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? no
Is there an existing well log? yes
If yes, what is replacement well NO? _____
If yes, what is NDWR well log #? 106272

4 EXISTING WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	8.68	.413	0	20

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	To
hand slotted	1/4"	10 feet	20 feet

If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used:
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
Static water level 6.5 feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

6 Additional Notes or Comments

From	To	Material Used	Pumped	Poured
0	20	neat cement	<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>

No pump in well. Installed tremme, pumped in neat cement and pulled casing from well.

Neat Cement Fluid Weight 14.5 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 10/7/2013
Date Completed 10/9/2013

DW-20
38.447733°N
119.749333°W
2013-10-09 AM 2:10
STATE ENGINEER'S OFFICE
plugs well log 10/22/13

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Carson Pump, LLC Contractor
Address P.O. Box 20159 Contractor
Carson City, NV, 89721
Nevada contractor's license number issued by the State Contractor's Board 39920A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2265
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 10/22/2013