STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 118578
Permit No. 82948T
Basin 103

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69889

1. OWNER RON TRUNK
MAILING ADDRESS 7575 IRON MOUNTAIN BLVD
STAGECOACH, NV 89444

ADDRESS AT WELL LOCATION 7575 IRON MOUNTAIN BLVD
STAGECOACH, NV 89444
Subdivision Name: County: Lyon

2. LOCATION NW ¼ SW ¼ Sec 18 T 17N N/S R 23 E
PERMIT/WAIVER No. 82948T (Issued by Water Resources) 015-362-20 Parcel No.
Latitude 39.337534*N
Longitude 119.451379*W
UTM E ☐ NAD 27
N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☒ ~~Irrigation~~ / Comm ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
COBBLES AND GRAVELS		3	46	43
OBSIDIAN GRAVELS		46	131	85
BROWN CLAY SEAMS		131	168	37
GRAVELS				
BROWN CLAY		168	200	32
SMALL OBSIADIAN GRAVELS				
FRACTURED GRAVELS	XXX	200	270	70

RECEIVED 2013 NOV 2 AM 8:01 STATE ENGINEERS OFFICE

Date started: 11-Nov, 20 13
Date completed: 19-Nov, 20 13

9. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 3/4	Inches	0	Feet	270	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.34	.188	2	270

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3X 3/32
From 210 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 100 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 270 ☐ Pumped ☒ Poured
Type: 3/8 PEAT GRAVEL
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 110 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125+	75	3 HRS

NAD27
39.435689°N
119.450325°W

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed (By driller performing actual drilling on site or contractor)
Date 11/20/2013

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY