

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 119751
Permit No. _____
Basin 105

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

1 OWNER BENTLY NEVADA CORP/Bentley Family LTD ADDRESS AT WELL LOCATION (O Milky Way Rd.) NE MINDEN HEYBORNE RD AND
MAILING ADDRESS 1617 WATER ST AIRPORT RD MINDEN, NV 89423
MINDEN, NV 89423
Subdivision Name: _____ County: Douglas

2 LOCATION NE 1/4 SW 1/4 Sec 8 T 13N N/S/R 20 E Latitude 39.00469°N UTM E NAD 27
PERMIT/WAIVER No. 1320-08-001-011 Longitude 119.76205°W N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NO? _____
Is there an existing well log? YES
If yes, what is NDWR well log #? 28723
28722

4 EXISTING WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/FT (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>8.67</u>	<u>.188</u>	<u>0</u>	<u>230</u>

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____
Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made: _____

Existing Perforations:

Type of perforation	Size of perforation	From	To
<u>FACTORY STAINLESS STEEL</u>	<u>0.02</u>	<u>220</u>	<u>230</u>

Additional Perforations:

Type of perforator used:	From	feet to	feet	Number of perfs per linear foot
<u>N/A</u>				

5 WATER LEVEL
Static water level 63 feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature N/A °F Quality N/A

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<u>0</u>	<u>230</u>	<u>feet</u>	<u>NEAT CEMENT</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
PLACED 1 1/4 TREEMIE PIPE TO BOTTOM AND FULL OF NEAT CEMENT.
39.004782°N NAD83
119.761039°W
Plugged well log # 28723
STATE ENGINEERS OFFICE
10-11-11 67 130 7107

Neat Cement Fluid Weight 94/4 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 10/17/2012
Date Completed 10/17/2012

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SYSTEM INC.
Contractor
Address 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 10/19/2012

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY