

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 118951  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36832

1. OWNER Public Right of Way (Clark County) ADDRESS AT WELL LOCATION None  
MAILING ADDRESS 5005 Grand Central Pkwy Kolva & Tropicana  
Las Vegas, NV 89155 Subdivision Name: \_\_\_\_\_ County: Clark

2. LOCATION SE 1/4 SW 1/4 Sec 21 T 21 N R 61 E Latitude 36.101734 UTM E  NAD 27  
PERMIT/WAIVER No. 162-21-499-004 Longitude -115.163903 N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Cable  
 Municipal/Industrial  Monitor  Stock  Air  Other

5. WELL TYPE  
 Rotary  RVC  
 Other

6. LITHOLOGIC LOG

| Material                 | Water Strata | From      | To        | Thick-ness |
|--------------------------|--------------|-----------|-----------|------------|
| <u>Pavement</u>          |              | <u>0</u>  | <u>.5</u> | <u>.5</u>  |
| <u>Type II</u>           |              | <u>.5</u> | <u>2</u>  | <u>1.5</u> |
| <u>Sandy clay</u>        |              | <u>2</u>  | <u>8</u>  | <u>6</u>   |
| <u>caliche</u>           |              | <u>8</u>  | <u>11</u> | <u>3</u>   |
| <u>Sandy w/some clay</u> |              | <u>11</u> | <u>20</u> | <u>8</u>   |
|                          | <u>13</u>    |           |           |            |

DGN/DWR/SNBO  
RECEIVED  
SEP 16 2013

9. WELL CONSTRUCTION

| Depth Drilled | Feet | Depth Cased | Feet |
|---------------|------|-------------|------|
| <u>20</u>     |      | <u>20</u>   |      |

HOLE DIAMETER (BIT SIZE)

|                 | From          | To             |
|-----------------|---------------|----------------|
| <u>6</u> Inches | <u>0</u> Feet | <u>20</u> Feet |
| _____ Inches    | _____ Feet    | _____ Feet     |
| _____ Inches    | _____ Feet    | _____ Feet     |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2"</u>          | <u>PVC</u>          | <u>Sch 40</u>           | <u>0</u>    | <u>20</u> |
| _____              | _____               | _____                   | _____       | _____     |

Perforations:

Type of perforation Factory slot  
Size of perforation .020

From 5 feet to 20 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout .5 to 2  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 4 to 20  Pumped  Poured  
Type: #12 silica

Bentonite Chips:  Yes  No 4 to 2  Pumped  Poured  
Type: Hole plug

Date started: 8/7, 2013  
Date completed: 8/7, 2013

7. Water Level  
Static water level: \_\_\_\_\_ feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

| TEST METHOD:                                                                                    | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-------------------------------------------------------------------------------------------------|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift |        |                               |              |
|                                                                                                 |        |                               |              |
|                                                                                                 |        |                               |              |
|                                                                                                 |        |                               |              |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elite Drilling Inc.  
Address 4255 W. Post rd  
Las Vegas NV 89118  
Nevada contractor's license number 0054931  
issued by the State Contractor's Board  
Nevada driller's license number issued by the M-1869  
Division of Water Resources, the on-site driller

Signed [Signature]  
By driller performing actual drilling on-site or contractor

Date 9-5-13