WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 119040
Permit No.
Basin 162

NOTICE OF INTENT NO. 33116

1. OWNER Fred & Carol Green
MAILING ADDRESS P.O. Box 6720
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
4171 W. Tiger Pahrump, NV

2. LOCATION N/E 1/4 S/E 1/4 Sec. 26 T 20S N/S R 52E E NYE County
PERMIT NO. _____ Issued by Water Resources | 28-613-17 Parcel No. | Vegas Acres Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
See next line		0	35	35
grey clay with caleche strings				
brown clay	x	35	121	86
brown clay with gravel	x	121	170	49

DCNR/DWR/SNBO
RECEIVED
OCT 28 2013

Date started 10/21/1913 2013 DSB, 19__
Date completed 10/21/1913, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	170	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	170

Perforations:
Type perforation sawcut
Size perforation .188
From 140 feet to 170 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc.
Contractor
Address 5801 S. Homestead
Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [signature]
By driller performing actual drilling on-site or contractor
Date 10.23.13

36° 10.783 NAD 83
116° 05.356

36.1797558 NAD 27
-116.0884051