

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

**OFFICE USE ONLY**  
Log No. 119066  
Permit No. \_\_\_\_\_  
Basin No. 212

**PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 37077  
WELL NAME (if applicable): OMW72-77

1. OWNER/CLIENT NAME Ms Rose Pelino, Avis Budget Car Rent  
MAILING ADDRESS 6 Sylvan Way  
Parsippany, NJ, 07054

DETAILED ADDRESS AT WELL LOCATION \_\_\_\_\_  
Wilbur Street & Lulu Ave, Las Vegas  
Subdivision Name: \_\_\_\_\_ County: Clark

2. PLS LOCATION NW 1/4 NE 1/4 27 Sec 21S N/S 61 E  
PERMIT/WAIVER NO. \_\_\_\_\_  
*Issued by Water Resources Current Parcel No*

Latitude 36°5'56" N UTM E \_\_\_\_\_  NAD 27  
Longitude 115°8'26" W UTM N \_\_\_\_\_  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG					
Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Asphalt			0		
Type II Base				1	1
Caliche			1	11	10
Gravelly Sand			11	19	8
Silty gravel with sand			19	26	7
lean clay with gravel			26	29	3
Gravelly Silt with sand			29	34	5
lean clay with gravels			34	37	3
poorly graded sand, silt			37	41	4
lean clay trace gravel			41	46	5
Hard pack clay			46	50	4
gravelly lean clay			50	54	4
well graded sand with gra			54	63	9
porly graded gravel silt			63	65	2
lean clay gravels			65	72	7
silty, sand, gravel			72	77	5

9. WELL CONSTRUCTION  
Depth Drilled: 77 Feet Depth Cased: 77 Feet

HOLE DIAMETER (BIT SIZE)				
	From	To		
	<u>6 5/8</u> Inches	<u>0</u> Feet	<u>77</u> Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.68</u>	<u>0.154</u>	<u>- .50</u>	<u>77</u>

PERFORATIONS:  
Type of perforation: Factory  
Size of perforation: 0.02  
From 72 Feet To 77 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

ANNULAR MATERIALS  
 Sanitary Seal 65 to 69  Pumped  Poured  
 Neat Cement -1 to 2  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Grout 2 to 65  Pumped  Poured  
 15%  20%  Other, explain: \_\_\_\_\_  
 Gravel Pack [ > 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] 65 to 77  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: 19-Nov 20 13  
Date completed: 19-Nov 20 13

7. WATER QUALITIES  
Static water level: 75 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ ° Fahrenheit  
Water Quality: Clear

8. WELL TEST DATA			
Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name National EWP Contractor  
Address 5566 Arrow Highway, Montclair, CA 91763 Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 00735355  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2057  
Signed: \_\_\_\_\_  
Date: 12/23/13

(Rev. 06-12)

USE ADDITIONAL SHEETS IF NECESSARY

36.9188  
-115,14055