WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 119102
Permit No.
Basin 105

NOTICE OF INTENT NO. 65548

1. OWNER Jamie Lynn Mott
MAILING ADDRESS 1825 Sunrise Pass
Minden NV 89423

ADDRESS AT WELL LOCATION 142 Orchard
GUNU

2. LOCATION NE ¼ SW ¼ Sec. 34 T 13 N/S R 20 E Douglas County
PERMIT NO. DUM3171 (Issued by Water Resources) 1320-34-002-052 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	12	12
Sand		12	16	4
Brown clay		16	26	10
Med to large Gravel		26	64	38
large Gravel & Sand		64	68	4
Dense clay		68	73	5
Assorted Gravel		73	103	30
Sticky clay		103	115	12
Small to Med. Gravel		115	138	23
Dense clay with		138	1	
Chiped Rock		1	147	9
Assorted Size Gravel		147	160	13
38° 56.805				
119° 43.674				
NAD83				
NAD27				
38.946843° N				
119.926890° W				

Date started 11-4-13, 20
Date complated 11-6-13, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
140 FT	35+		3.5

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	107 Feet
9 7/8 Inches	107 Feet	160 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	160

Perforations:
Type perforation Factory
Size perforation 1/16 x 4
From feet to feet
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 102
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 102 feet to 160 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow N/A G.P.M. 35+ P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling (Contractor)
Address PO 1255 CC NV 89702 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 46498A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2321
Signed C. Robinson (By driller performing actual drilling on site or contractor)
Date 11-18-13

RECEIVED JAN 27 AM 11:48 STATE ENGINEER'S OFFICE

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627