

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY  
Log No. 119122  
Permit No. \_\_\_\_\_  
Basin 101

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69808

1 OWNER Department of the Navy ADDRESS AT WELL LOCATION 50' off tarmac 400' NE of tower  
MAILING ADDRESS 4755 Pasture Rd., Fallon, NV Subdivision Name: PZ-6-2 County: Churchill  
LOCATION NE 1/4 3E 15 T 18N N/S/R 28 E Latitude 39 25 26.21 N UTM E  NAD 27  
PERMIT/WAIVER No. 006-011-01 Longitude -118 42 29.83 W N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? No Is there an existing well log? NA  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock If yes, what is replacement well NOI? \_\_\_\_\_ If yes, what is NDWR well log #? \_\_\_\_\_

4 EXISTING WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	7.5	Feet
---------------	------	-------------	-----	------

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
.75		Sch. 40	0	7.5

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: Bottom of the well was tagged  
Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no  
If casing was left in place, please show where additional perforations were made: \_\_\_\_\_  
Additional Perforations: \_\_\_\_\_

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet

Type of perforator used: none

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL

Static water level 5.83 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ ° F Quality \_\_\_\_\_

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	neat	<input type="checkbox"/> Pumpe	<input checked="" type="checkbox"/> Poured
0	7.5	feet			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
					<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
					<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
					<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
					<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

6 Additional Notes or Comments  
completion was pulled and filled with native soil

Neat Cement Fluid Weight 1 Gal lbs/gal  
Bentonite Grout % bentonite  
Date Started 1/16/2014  
Date Completed 1/16/2014

*plug unknown log*  
*NAD 27*  
*39 25 26.21 N*  
*118 42 29.83 W*

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name National EWP Contractor  
Address 500 Main St. Woodland, CA 95695 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0075355  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 1-27-14