STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114492
Permit No.
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70758

1. OWNER Pauline Lambert
MAILING ADDRESS P.O. Box 1746
Winnemucca NV.

ADDRESS AT WELL LOCATION 3030 Summerwind Dr.
Winnemucca NV.
Subdivision Name: 5 mile acres County: Humboldt

2. LOCATION SE ¼ NW ¼ Sec 21 T 37 N/S R 38 E
PERMIT/WAIVER No. 006-515-01
Issued by Water Resources Parcel No.

Latitude N 41° 04.377
Longitude W 117° 42.496
UTM E N
■ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | NO | 0 | 5 | 5 |
| Gravel Sand Clay | NO | 5 | 50 | 45 |
| Gravel Sand | yes | 50 | 65 | 15 |
| Soft brown clay | yes | 65 | 100 | 35 |

Nad 27
41.072450° N
117.709267° W

Date started: 1-24, 20 14
Date completed: 1-28, 20 14

RECEIVED 2014 FEB 24 AM 11:50 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 7/8 | Inches | 0 | Feet | 100 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 7/8 | Steel | .188 | 0 | 20 |
| 6 5/8 | PVC | Sched 40 | 20 | 100 |

Perforations:
Type of perforation Slot
Size of perforation .020
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 20 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 50 to 100 ☐ Pumped ■ Poured
Type: 3/8" Pea
Bentonite Chips: ■ Yes ☐ No 20 to 50 ☐ Pumped ■ Poured
Type: 3/8" Chip

7. Water Level
Static water level: 52 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15 | NA | 4 |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Junga Rd. (Contractor)
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 1-28-14

(Rev. 05-09)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627