STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119498
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71412
WELL NAME (If applicable):

1. OWNER/CLIENT NAME MIKE AND DEBRA BROWN
MAILING ADDRESS 810 EAGLE MEADOWS RD
GAEDNERVILLE, NV 89460

DETAILED ADDRESS AT WELL LOCATION 810 EAGLE MEADOWS RD
GARDNERVILLE, NV 89460
Subdivision Name: County: Douglas

2. PLS LOCATION SW ¼ SW ¼ 13 Sec 12 N/S 19 E
PERMIT/WAIVER NO. 1219-14-002-083
Issued by Water Resources Current Parcel No.

Latitude 38.897163*N UTM E ☐ NAD 27
Longitude 119.806343*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
COURSE DG SANDS		X	3	35
COURSE GRAVELS			35	62
DG SANDS AND SILT			62	135
HARD PAN DG SANDS		XXX	135	180

RECEIVED 2014 FEB 18 AM 11:06 STATE ENGINEERS OFFICE

Date started: 12-Feb, 20 14
Date completed: 13-~~Dec~~ Feb, 20 14

9. CONSTRUCTION
Depth Drilled: 180 Feet Depth Cased: 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	180

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout	0	to	100	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	180	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 3 X 3/32

From		Feet	To		Feet
From	160	Feet	To	180	Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet

7. WATER QUALITIES
Static water level: 0 Feet below land surface
Artesian Flow: 2 G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
35+	40	3 HRS

Nad 27
39.89 7 9760 N
119.805382 0 W

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITRAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE, CARSON CITY, NV 89706
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905

Signed: Michael Stack
By driller performing actual drilling on site or contractor
Date: 2/14/2014