STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119528
Permit No.
Basin No. 072

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67147
WELL NAME *(If applicable)*: MW-15

1. OWNER/CLIENT NAME TA Operations LLC
MAILING ADDRESS 24601 Center Ridge Road Ste 200
Westlake, OH 44145

DETAILED ADDRESS AT WELL LOCATION Facility ID: 5-000016
6000 F Frontage Road Inlay, NV 89418
Subdivision Name: County: ~~Washoe~~ Pershing

2. PLS LOCATION SW ¼ NW ¼ 33 Sec 33N N/S 35 E
PERMIT/WAIVER NO. 008-130-01
Issued by Water Resources *Current Parcel No.*

Latitude 40.693622 UTM E ☐ NAD 27
Longitude 118.056592 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Hard Pan			0	20	20
Clay, Dense			20	40	20
Clay, Semi-Silty Mix			40	60	20
Sandy Silt			60	75	15

Date started: 24-Oct, 20 13
Date completed: 24-Oct, 20 13

Nad 27
40.693622 N
118.056561 W

RECEIVED
2013 OCT 15 AM 11:52
STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled: 75 Feet Depth Cased: 75 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	75	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40	0	75

PERFORATIONS:
Type of perforation: Slot
Size of perforation: 0.01
From 45 Feet To 75 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☐ Sanitary Seal		to			
☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	40	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	40	to	43	☐ Pumped	☒ Poured
☐ Bentonite Grout		to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:					
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	43	to	75	☐ Pumped	☒ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Cascade Drilling, L.P.
Contractor
Address 3000 Duluth Street West Sacramnto, CA 95691
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 73966
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2467

Signed:
By driller performing actual drilling on site or contractor
Date:

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY