

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35467

1. OWNER John + Peggy Ellenburg ADDRESS AT WELL LOCATION Woods + Paloma  
 MAILING ADDRESS P.O. Box 9370 Sands Valley NV  
Las Vegas NV 89193  
 2. LOCATION SE 1/4 SW 1/4 Sec 23 T 24 N R 56 E Clark County  
 PERMIT NO. 20023/401/30 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand Loam	<del>W.B</del>	0	4	4
Clay		4	36	36
Caliche		36	42	6
Caliche	W.B	42	46	4
Clay	W.B	46	101	55
Caliche	W.B	101	135	34
<del>35° 50.374 N</del>				
<del>115° 39.977 W</del>				
<del>elev 2677</del>				
35° 50.363 N				
115° 39.952 W				
elev 2656				
DONE/DWR/SNBO RECEIVED				
FEB 11 2014				

8. WELL CONSTRUCTION  
 Depth Drilled 135 Feet Depth Cased 135 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10.5 Inches To 135 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.95</u>		<u>0.32</u>	<u>0</u>	<u>135</u>
<u>6.58</u>		<u>.198</u>	<u>+2</u>	<u>8</u>

Perforations:  
 Type perforation factory screen  
 Size perforation 1.032  
 From 95 feet to 135 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 200C °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Budget Drilling LLC Contractor  
 Address 1170 Darcy Pahrump Contractor  
NV 89060  
 Nevada contractor's license number issued by the State Contractor's Board 0077029  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 2-3-14

Date started 1-25, 2014  
 Date completed 1-25, 2014

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>unknown</u>	<u>1</u>