WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 119566
Permit No.
Basin 163

NOTICE OF INTENT NO. 36790

1. OWNER Jay + Terra Conner
MAILING ADDRESS 4410 Pebble
Las Vegas NV 89139
ADDRESS AT WELL LOCATION 1630 Cicchi ST
Sandy Valley NV

2. LOCATION SW ¼ NW ¼ Sec 26 T. 24 N/S R. 56 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 200-26-201-002 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 20 | 20 |
| Calichie / Clay | | 20 | 44 | 14 |
| Calichie / Clay | W.B | 44 | 58 | 14 |
| Calichie / Clay | W.B | 58 | 100 | 42 |
| Calichie / Clay | W.B | 100 | 135 | 35 |

N
4 W
050.03
35 40.232
115

elev 2664

DCNR/DWR/SNBO
RECEIVED
FEB 11 2014

Date started 2-1, 2014
Date completed 2-1, 2014

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 46 | | 1 |

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 10.5 | 0 | 135 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.95 | | Certificate | 0 | 135 |
| 6 5/8 | | .188 | +2 | 8 |

Perforations:
Type perforation factory Screen
Size perforation .032
From 95 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Budget Drilling LLC (Contractor)
Address 1170 Darcy Pahrump (Contractor)
NV 89060
Nevada contractor's license number issued by the State Contractor's Board 0077029
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 2-3-14

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY

35.8339958
-115.6696756
NAD 27