STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119692
Permit No. 16795
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55914

1. OWNER Toomey Real Estate LLC
MAILING ADDRESS 5538 Duncan
ADDRESS AT WELL LOCATION 5538 DUNCAN LV, NV 89122
Subdivision Name: County:

2. LOCATION NE¼ NW¼ Sec 12 T 20 N OR 60 E
PERMIT/WAIVER No. 16795 (Issued by Water Resources) 138-12-110-05 (Parcel No.)
Latitude N 36.229297336 Longitude W -115.217771725
UTM E N ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other ABANDON

4. PROPOSED USE
☒ Domestic COM ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cement well according to waiver Dated 11-25-73				
In 1973 well was test pumped and well was never in service since. well collasped with Turbine pump still in well top of pump 110 ft. will perforate from 110 ft up Neat cement all the way up to surface				
* Original log 3814				
Reperforated from 110 up				

Date started: NOV 25, 2013
Date completed: NOV 26, 2013

7. Water Level
Static water level: 75 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR/SNBO RECEIVED FEB 04 2014

9. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 283 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	325	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.07	.250	0	283

Perforations:
Type of perforation Air Perforator Rotary
Size of perforation 3/16 x 4 Row
From 0 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Vernon H. Dimick
Address (Contractor) 13040 Horse Dr.
Las Vegas NV 89166
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V.H. Dimick
(By driller performing actual drilling on-site or contractor)
Date Feb 3-14

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 36.2293298 -115.2169339

(NSPO 3-08) (O) 627