STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119735
Permit No. 83329-T
Basin 137B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70640

1. OWNER Round Mountain Gold Corp. DW-64
MAILING ADDRESS P.O Box 480, Round Mountain, NV. 89045

ADDRESS AT WELL LOCATION Round Mountain Mine Site, Round Mountain, NV
Subdivision Name: County: Nye

2. LOCATION SW¼NE¼ Sec30T10N/ R44E
PERMIT/WAIVER NO. 83329-T
Issued by Water Resources Parcel. No.

Latitude UTM E 493149 ☒ NAD 27
Longitude N 4283097 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ ~~Monitor~~ DW ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Flooded Rev

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
White Rock W/Clay		0	150	150
Grey Rock W/Some Clay		150	220	70
Black Rock W/Some Clay		220	230	10
Grey Rock W/Clay		230	380	150
Light Grey Rock W/Clay		380	490	110
Light Grey Rock		490	500	10
Light Grey Rock W/Clay		500	570	70
Light Grey Rock		570	600	30
Grey Rock W/Clay		600	770	170
White And Grey Rock W/Clay		770	830	60
Grey Rock W/Clay		830	900	70
Black and Grey Rock W/Clay		900	910	10
Grey Rock W/Light Grey Clay		910	1000	90

Nad 27
38.498335° N
117.078783° W

Date started: February 16, 20 14
Date completed: March 5, 20 14

9. WELL CONSTRUCTION

Depth Drilled 1000 Feet Depth Cased 1000 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
26 Inches	0 Feet	35 Feet
19 Inches	35 Feet	1000 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
22	86.608	.375	0	37
12.75	33.375	.250	+2	1000

Perforations:
Type of perforation Louver
Size of perforation .125
From 660 feet to 960 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 60 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 405 to 1000 ☐ Pumped ☒ Poured
Type: 1/2 X 3/4 SRI Supreme
Bentonite Chips: ☒ Yes ☐ No 60 to 405 ☒ Pumped ☐ Poured
Type: 3/8" Hole plug

7. Water Level
Static water level: 300 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: 118 °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8	617	2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2486
Signed [signature]
By driller performing actual drilling on site or contractor
Date March 20, 2014

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

Plugged by Well log 122685