STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119740
Permit No. 78454
Basin 177

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69077

1. OWNER F. Scott & Laurel S. Egbert
MAILING ADDRESS HC 60 Box 135
Wells, NV 89835

ADDRESS AT WELL LOCATION 7 miles South on 232 from Junction @ Hwy 93 & 232
Subdivision Name: County: Elko

2. LOCATION NW ¼ SE ¼ Sec 36 T 36 N/S R 61 E
PERMIT/WAIVER No. 78454 Issued by Water Resources
Parcel No.
Latitude 40.957099
Longitude 115.029129
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other- Repair

4. PROPOSED USE
☒ ~~Domestic~~ ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drilled out gravel & reseal well. Broke casing. Had to drill through surface seal, through casing & other. Cement from bottom up & re-set casing, gravel pack and surface seal.				
See Well log # 116304				

Date started: 11-5, 2013
Date completed: March 17, 2014

9. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
26	Inches	0	Feet	350	Feet
12	Inches	350	Feet	780	Feet
9 7/8	Inches	780	Feet	1000	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.250	+2	40
6.625		SDR17	40	350'

Perforations:
Type of perforation mill
Size of perforation 19 x 2 1/2
From 120 feet to 160 feet
From 180 feet to 200 feet
From 220 feet to 240 feet
From 330 feet to 350 feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	0 to 50	☐ Pumped	☐ Poured
☒ Cement Grout	350 to 1000	☒ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 350 ☐ Pumped ☐ Poured
Type: 3/4" gravel
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		2 HRS.
Nad 27		
40.957175°N		
115.029219°W		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Gardner Brothers Drilling
Address (Contractor) PO Box 965
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources the on-site driller 2458
Signed (By driller performing actual drilling on-site or contractor)
Date 3-18-14

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627