

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 119489
Permit No. _____
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

1 OWNER BENTLY NEVADA CORP. / Bently Family LTD. ADDRESS AT WELL LOCATION WITT PROPERTY NOTICE OF INTENT NO. 69619
MAILING ADDRESS 1617 WATERS ST AIRPORT RD AND HEYBORNE RD, MINDEN NV 89423
MINDEN, NV 89423

2 LOCATION NE 1/4 SW 1/4 Sec X8 T 13N N/S R 20 E Latitude 39.00349°N UTM E NAD 27
PERMIT/WAIVER No. 1320-08-002-006 Longitude 119.76135°N N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3 TYPE OF WELL Domestic Irrigation Test Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? NO Is there an existing well log? YES
If yes, what is replacement well NO? _____ If yes, what is NDWR well log #? unknown - MW-12B

4 EXISTING WELL CONSTRUCTION

Depth Drilled 60 Feet Depth Cased 60 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>8.67</u>	<u>.188</u>	<u>+3</u>	<u>54</u>

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: WELL HAD A BRIDGE SPOT AT 12 FT. FLUSHED WELL WITH CLEAR WATER AND WASHED TREEMIE PIPE TO 46'. PUMPED FULL WITH NEAT CEMENT TO SURFACE

Existing Perforations:

Type of perforation	Size of perforation	FACTORY CUT
From <u>50</u> feet to <u>60</u> feet	<u>0.032</u>	
From _____ feet to _____ feet		
From _____ feet to _____ feet		
From _____ feet to _____ feet		
From _____ feet to _____ feet		

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations: _____
Type of perforator used: N/A

From	feet to	feet	Number of perms per linear foot
From _____	feet to _____	feet	_____
From _____	feet to _____	feet	_____
From _____	feet to _____	feet	_____
From _____	feet to _____	feet	_____
From _____	feet to _____	feet	_____
From _____	feet to _____	feet	_____

5 WATER LEVEL

Static water level N/A feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature N/A °F Quality N/A

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From <u>0</u>	feet to <u>54</u>	feet	<u>NEAT CEMENT</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>
From _____	feet to _____	feet		<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments

WELL HAD A BIRT BRIDGE IN WELL AT 12ft WASHED CLEAR WATER TO CLEAN OUT BRIDGE AREA AND THEN PUMPED FULL OF NEAT CEMENT TO SURFACE.

Plugs well log# unknown

Neat Cement Fluid Weight 94/4 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 10/17/2012
Date Completed 10/17/2012

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. Contractor
Address 20 KIT KAT DRIVE Contractor
CARSON CITY, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed [Signature] By driller performing actual drilling on-site or contractor
Date 10/19/2012

(Rev. 05-01) 39.003582°N
119.760339°W

USE ADDITIONAL SHEETS IF NECESSARY