

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36386

1. OWNER Cold Creek Canyon HOA ADDRESS AT WELL LOCATION Pinion & Rudin (Stella Circle & Rudin Dr.)
 MAILING ADDRESS P.O. Box 12117 Las Vegas NV. 89112

2. LOCATION NE 1/4 SE 1/4 Sec. 1 T. 18 N/S R. 55 E CLARK County
 PERMIT NO. 36526 Issued by Water Resources Parcel No. 095-01-711-111 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Dirt - Rocks		0	60	60
Black Rock Dirt		60	240	180
Black Sand Gravel	✓	240	310	70
Black Dolomite Rock	✓	310	400	90

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 382 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 400 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.188</u>	<u>41</u>	<u>299</u>
<u>6 5/8</u>		<u>.188</u>	<u>295</u>	<u>382</u>

Perforations:
 Type perforation Saw & Factory
 Size perforation 1/8 x 6 .030
 From 382 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 99 + Neat Cement
 Placement Method: Pumped 12 Sack Cement Grout
 Poured SLURRY Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 95 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Redding Drilling Contractor
 Address P.O. Box 231120 Contractor
Las Vegas NV 89105
 Nevada contractor's license number 38155
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2160
 Division of Water Resources, the on-site driller
 Signed Randy Rudin Manuel Building
 By driller performing actual drilling on site or contractor
 Date 3-5-14

Date started 8-26- 2013
 Date completed Feb 10 2014

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
 2014 APR 18 AM 9:11
 CIVIL ENGINEERS OFFICE

DCNR/DWR/SNRC
 RECEIVED
 MAR 05 2014

NAD83/WGS84
 36°24'48.42"N
 115°44'36.50"W