STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119828
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71419
WELL NAME (If applicable):

1. OWNER/CLIENT NAME BONNIE PARK
MAILING ADDRESS 1280 CENTERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION 1280 CENTERVILLE, NV 89410
Subdivision Name: County: Douglas

2. PLS LOCATION NW ¼ SW ¼ 4 Sec 12 N/S 20 E
PERMIT/WAIVER NO. 1220-04-002-004
Issued by Water Resources Current Parcel No.

Latitude 38.930656*N UTM E ☐ NAD 27
Longitude 119.748925*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVERBURDEN			0	3
COBBLES AND MORE COBBLES			3	65
RIVER COBBLES			65	105
GRAVELS			105	135
FRACTURED COBBLES	XXX		135	160

RECEIVED 2014 APR 14 PM 2:16 STATE ENGINEERS OFFICE

Nad 27
38.930749°N
119.747917°W

Date started: 25-Mar, 20 14
Date completed: 27-Mar, 20 14

7. WATER QUALITIES
Static water level: 12 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25+	30	3 HOURS

9. INSTRUCTION
Depth Drilled: 160' Feet Depth Cased: 160' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8	4.26	.216	20	160
SDR 17				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	100	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	160	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY SLOT
Size of perforation: 0.0323

From	120	Feet	To 160	Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE, CARSON CITY, NV 89706
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905
Signed: Michael F Hack
By driller performing actual drilling on site or contractor
Date: 3/27/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.