STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119830
Permit No.
Basin No. 059

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71418
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME KINO GUITIERREZ
MAILING ADDRESS 230 McCLELLAN
NEW WASHOE CITY, NV 89704

DETAILED ADDRESS AT WELL LOCATION 230 McCLELLAN
NEW WASHOE CITY, NV 89704
Subdivision Name: *County:* Washoe

2. PLS LOCATION NW ¼ SW ¼ 32 Sec 17 N/S 20 E
PERMIT/WAIVER NO. 050-397-12
Issued by Water Resources *Current Parcel No.*

Latitude 39.292891*N UTM E ☐ NAD 27
Longitude 119.766735*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# ~~23289~~
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OLD 8 5/8 WELL			0	155
FOREIGN MATERIALIN BOTTOM				
SMALL DG GRANITE			155	195
HARD FRACTURED GRANITE			195	237
HARD GRANITE			237	260
FRACTURED GRANITE	XXX		260	295
Nad27				
39.29248 N				
119.7705 W				
Deepen well log unknown				

Date started: 2-Apr , 20 14
Date completed: 4-Apr , 20 14

7. WATER QUALITIES
Static water level: 125 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20-25	65	3 HRS

9. CONSTRUCTION
Depth Drilled: 140 Feet Depth Cased: 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	155	Feet	295	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.26	.216	155	295
SDR 21				

ANNULAR MATERIALS

Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout	N/A	to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	N/A	to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 0.032

From 255	Feet	To 295	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT AKT DRIVE, CARSON CITY, NV 89706
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1905

Signed: [signature]
By driller performing actual drilling or his or contractor
Date: 4/4/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.