STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119848
Permit No.
Basin No. 125

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71420
WELL NAME (if applicable):

1. OWNER/CLIENT NAME ROBERT AND WENDY CARR
MAILING ADDRESS 1012 KEYSTONE CT
GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION 840 RUBIO WAY
GARDNERVILLE, NV 89460
Subdivision Name: County: Douglas

2. PLS LOCATION NW ¼ SE ¼ 17 Sec 12 N/S 20 E
PERMIT/WAIVER NO. DOM-14-14 (Issued by Water Resources) 1220-17-710-016 (Current Parcel No.)

Latitude 38.899787*N UTM E ☐ NAD 27
Longitude 119.757655*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
COURSE GRAVELS			3	95
SMALL DG SANDS AND GRAV			95	162
BROWN SILTY CLAY				
GRAVELS			162	185
COURSE OBSIDIAN GRAVELS			185	220

Date started: 8-Apr , 20 14
Date completed: 11-Apr , 20 14

7. WATER QUALITIES
Static water level: 55 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	105	3 HRS

9. INSTRUCTION
Depth Drilled: 220 Feet Depth Cased: 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	20
6 5/8	4.26	.216	20	220
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	0	to 100	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to 220	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: 3 X 3/2

From	Feet	To	Feet
180		220	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE, CARSON CITY, NV 89706 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905
Signed: Michael A. Hack (By driller performing actual drilling on site or supervisor)
Date: 4/11/2014

2014 APR 15 AM 10:17
RECEIVED
NEVADA DIVISION OF WATER RESOURCES

Nad 27
38.899787°N
119.756645°W

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.