

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 114 851  
Permit No. \_\_\_\_\_  
Basin 071

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70764

1. OWNER Matthew Cameron ADDRESS AT WELL LOCATION 9200 Zaring  
MAILING ADDRESS 9200 Zaring Blvd. Winnemucca NV. Subdivision Name: Zaring-Tycana County: Humboldt  
LOCATION SW 1/4 NE 1/4 Sec 30 T 350 S R 38 E Latitude N40°52.984 UTM E  NAD 27  
PERMIT/WAIVER No. 010-644-04 Longitude W117°44.622 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>	<u>NO</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>Boulders, gravel, sand</u>	<u>NO</u>	<u>5</u>	<u>140</u>	<u>135</u>
<u>Cemented gravel, sand</u>	<u>NO</u>	<u>140</u>	<u>300</u>	<u>160</u>
<u>Clay, sand</u>	<u>YES</u>	<u>300</u>	<u>320</u>	<u>20</u>
<u>Gravel, sand, clay</u>	<u>YES</u>	<u>320</u>	<u>360</u>	<u>40</u>

9. WELL CONSTRUCTION

Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10 7/8</u>	<u>0</u>	<u>360</u>	<u>360</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8 Steel</u>	<u>188</u>	<u>.188</u>	<u>0</u>	<u>20</u>
<u>6 7/8 PVC</u>	<u>Sched 40</u>	<u>.188</u>	<u>20</u>	<u>360</u>

Perforations:

Type of perforation slot  
Size of perforation .20

From	To	Feet
<u>300</u>	<u>360</u>	<u>360</u>

Annular Seal:  Yes  No

Neat Cement 0 to 20  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 50 to 360  Pumped  Poured  
 Type: 3/8" pea  
 Bentonite Chips:  Yes  No 20 to 50  Pumped  Poured  
 Type: 3/8" chip

Date started 3-24 , 20 14  
Date completed 4-7 , 20 14

7. Water Level  
Static water level: 240 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: cold °F  
Quality: clear

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>6</u>	<u>6</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allied Drilling Inc.  
Address 5140 Jungo Rd.  
Winnemucca NV.  
Nevada contractor's license number 76778  
issued by the State Contractors Board  
Nevada driller's license number issued by the 1563  
Division of Water Resources, the on-site driller

Signed [Signature]  
By driller performing actual drilling on-site or contractor  
Date 4-7-14