STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 119579
Permit No.
Basin No. 106

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70864
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Susan Haase
MAILING ADDRESS 1350 Dresslerville RD GV NV

DETAILED ADDRESS AT WELL LOCATION 1350 Dresslerville GV NV
Subdivision Name: *County:* Douglas

2. PLS LOCATION NE ¼ SE ¼ 9 Sec 12 N/S 20 E
PERMIT/WAIVER NO. Dom14-11 *Issued by Water Resources* ~~1-2201E+11~~ *Current Parcel No.*

Latitude 38 55.015 UTM E ☐ NAD 27
Longitude 119 44.026 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top soil			0	8
gravel			8	15
cobbels			15	20
sand gravel			20	28
sand			28	32
gravel			32	70
cobbels			70	76
sand gravel			76	95
clay			95	145
gravel			145	200

APN 1220-09-701-002
2014 APR 21 PM 12:13
STATE ENGINEER'S OFFICE
Vol 27
38.917010N
119.432757W

Date started: 10-Apr , 20 14
Date completed: 11-Apr , 20 14

7. WATER QUALITIES
Static water level: 65 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality: clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
air lift	20+		3.5

9. *INSTRUCTION*
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11" Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	2	17
6		SDR21	17	200

ANNULAR MATERIALS
Sanitary Seal x ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 102	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	102	to 200	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: factory
Size of perforation: 0.9
From 160 Feet To 200 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Blain Drilling *Contractor*
Address PO 1255 CC NV 89702 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 46498A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2134
Signed: *By driller performing actual drilling on site or contractor*
Date: 4/23/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.