DIVISION OF WATER RESOURCES
Sob No. 605

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 12065
Permit No.
Basin Washoe Val

1. OWNER Karl M. Keith ADDRESS 150 Brownstone Dr. Reno, Nevada

1770 East Lake Blvd. Lot 14, Block G Sub No. 1 50-298-10

2. LOCATION ¼ ¼ Sec. 30 T. 16 17 N/S R. 19 E. Washoe County

PERMIT NO.

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	7	7
Sandy clay & DG		7	43	35
clay		43	59	16
Sand & gravel	Yes	59	87	28
clay		87	88	1

Date started November 23, 1971
Date completed November 24, 1971

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	10	19	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 88 feet
Casing record
Weight per foot Thickness 188

Diameter		From		To	
6 5/8	inches	0	feet	88	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes [X] No [ ] Type Cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 88 feet to 50 feet

Perforations:
Type perforation Factory
Size perforation 1/8 x 3
From 88 feet to 67 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 29 Feet below land surface
Flow G.P.M.
Water temperature cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Glenn Pump and Drilling
Address 9310 Pan American Way
Nevada contractor's license number 11139
Nevada driller's license number 631
Signed J. M. Glenn
Date November 25, 1971

USE ADDITIONAL SHEETS IF NECESSARY

5471