

SW + SE + Sec 32

Sec 32 DCBD

WELL DRILLERS REPORT

APN = 050-391-08

Please complete this form in its entirety

Log No. 12240
 Permit No. _____
 Basin Washoe

1. OWNER Bill Knutson ^{orig} MARY WRIGHT ADDRESS 230 Drake; Washoe Valley;
Carson City, Nevada
 (Marv Mason-Contractor)

2. LOCATION 1/4 Sec 32 T. 17 N/S.R. 20 E Washoe County
 PERMIT NO. Lot #9; Block 0; Subdivision #5; Washoe Valley

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. topsoil		0	3	3
Sandy yellow clay		3	12	9
Sandy brown clay w/ coarse sand lenses		12	97	85
Sandy brown clay w/ some small gravels to 3/8" & coarse sand lenses		97	134	37
Weathered grey granite-partially decomposed-some perched water		134	150	16
Hard grey granite (water @ 210')	yes	150	220	70

Handwritten notes:
 N39, 289679
 W114, 756983 N1D2)
 see table under
 102, 62789

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 220 feet
 Casing record 6": 0-156'
 Weight per foot 12 lbs. Thickness 188

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>150</u> feet
<u>6</u> inches	<u>150</u> feet	<u>220</u> feet

Surface seal: Yes No Type cement slurry
 Depth of seal 84' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation none
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 11-2-71, 19____
 Date completed 11-5-71, 19____

9. WATER LEVEL
 Static water level 73 Feet below land surface
 Flow _____ G.P.M.
 Water temperature cold ° F. Quality not tested

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN:	<u>25GPM</u>	<u>52</u>	<u>1 1/2</u>

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co.
 Address 1955 18th. Street; Sparks, Nev.
 Nevada contractor's license number 9767
 Nevada driller's license number 493
 Signed [Signature]
 Date 1-10-72

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours