DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 12256
Permit No.
Basin Carson Des

1. OWNER Greenhof Dana ADDRESS 710 Wilds Road
423-5273
Mobile Home Park

2. LOCATION NE ¼ NW ¼ Sec. 6 T. 18 N/S R. 29 E. Churchill County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| top soil | | 0 | 2 | 2 |
| Clay | | 2 | 20 | 18 |
| Coars sand | | 20 | 24 | 4 |
| fine sand | | 24 | 30 | 5 |

Date started april 17, 1972
Date completed 11 19, 1972

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| 1750 | 20 | 5½ | 4½ |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 30 feet
Casing record 31 ft of 8"
Weight per foot 1690 Thickness 188

| Diameter | From | To |
|---|---|---|
| 12 inches | 0 feet | 10 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 10 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 10 feet to 30 feet

Perforations:
Type perforation Torch Cut
Size perforation 1/8 X 6
From 20 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 5½ Feet below land surface
Flow G.P.M.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Suede Welshenbaugh
Address P O Box 24 Hawy
Nevada contractor's license number 9105
Nevada driller's license number 494
Signed Suede Welshenbaugh
Date april 19 72

USE ADDITIONAL SHEETS IF NECESSARY

5471