DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 12625
Permit No.
Basin Washoe Val. CRRO

APN 50-387-18

1. OWNER Dixon Homes Inc. ADDRESS 2802 Kietzke Lane,
Reno, Nevada 89502
Home Location 2060 Lakeshore, Lot 18, Blk. K. Sub. 3 N.W.City.

2. LOCATION ¼ ¼ Sec. 31 T. 16N. N/S R. 20E. E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse + fine Sand		0	28'	28'
fine Sand		28'	40'	12'
sand + Clay		40'	55'	25'
Sand + Gravel		55'	70	15'

Date started Nov. 4, 1970, 19 70
Date completed Dec. Nov. 21, 19 70

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Sta-Rite			

BAILER TEST
G.P.M. 15 Draw down 35' feet ½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12" inches Total depth 50' feet
Casing record 6" To 70'
Weight per foot 13 lbs Thickness 3/16"

Diameter	From	To
10 inches	0 feet	50' feet
6 inches	0 feet	70' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Factory
Size perforation 1/8" x 3"
From 55' feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 10 Feet below land surface 10
Flow G.P.M. 15
Water temperature Cold ° F. Quality no Test made

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Pete Anderson
Address 3590 Churchill, New WASHOE City, Carson City,
Nevada contractor's license number 6432
Nevada driller's license number 307
Signed Pete Anderson
Date DEC. 1970

USE ADDITIONAL SHEETS IF NECESSARY

5471