DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 12917
Permit No.
Basin Golden Val

1. OWNER RENO BUILDING MATERIALS ADDRESS MILL STREET; RENO NEVADA
W.

2. LOCATION SW ¼ SE ¼ Sec. 11 T. 20N N/S R. 19 E. Washoe County
PERMIT NO. Lot #8; Golden Valley Ranches Unit #3-A; 3434 Sun Cloud; Golden Vly.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Reddish clay like decomposed granite sand damp		0	3	3
Yellow to brown clay like decomposed material very dusty		3	48	45
Blue gray silty clay like material		48	70	22
As above w/small broken granite mixed-2 GPM@ 70'		70	95	15
Broken gray granite 8 GPM@ 110' 70 GPM@ 125"		95	125	30

Date started 1-29, 19 73
Date completed 1-29, 19 73

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN	70 GPM @	125	depth

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 125 feet
Casing record 0-125 x6 5/8OD
Weight per foot 12.82 Thickness .188

Diameter		From		To	
10 5/8	inches	0	feet	53	feet
8	inches	53	feet	125	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Transit mix
Depth of seal 52 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation factory milled slot
Size perforation 1/8 x2½
From 85 feet to 125 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 35 Feet below land surface
Flow ..... G.P.M.
Water temperature 57 ° F. Quality not tested

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W.L. McDonald & Co
Address 1955 18th Street; Sparks Nev.
Nevada contractor's license number 9767
Nevada driller's license number 493
Signed .....
Date 1-29-73

USE ADDITIONAL SHEETS IF NECESSARY.

5471

OFFICE
STATE ENGINEER

1973 FEB 26 PM 3 34