

original

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 120001  
Permit No. \_\_\_\_\_  
Basin 137A

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71839

1. OWNER Steven Wright ADDRESS AT WELL LOCATION 1855 Seferd Lane  
MAILING ADDRESS PO Box 3522 Tonopah NV 89049  
Tonopah NV 89049 Subdivision Name: 6 County: NYE  
2. LOCATION NE 1/4 NW 1/4 Sec 13 T 6 N R 40 E Latitude: N 38° 23' 10.48" E  NAD 27  
PERMIT/WAIVER No. 0 12-421-28 Longitude: W 117° 25' 33.36" W  NAD 83/WGS 84

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>TOP Soil</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Bedders sand</u>		<u>10</u>	<u>60</u>	<u>50</u>
<u>Clay</u>		<u>60</u>	<u>70</u>	<u>10</u>
<u>gravel Bedders</u>	<u>X</u>	<u>70</u>	<u>140</u>	<u>70</u>
<u>Fractured Rock</u>	<u>X</u>	<u>140</u>	<u>178</u>	<u>120</u>

7' of 8" steel casing was cemented over 6" PUC casing at surface

9. WELL CONSTRUCTION  
Depth Drilled 178 Feet Depth Cased 178 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 178 Feet  
Inches 0 Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
6 1/2 PUC sch 40 0 178  
Perforations:  
Type of perforation saw cut  
Size of perforation 1/4" x 3"  
From 58 feet to 178 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout - 3 to 55  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured  
Gravel Pack:  Yes  No 55 to 178  Pumped  Poured  
Type: 3/8 minus  
Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 4-15-2014 , 20  
Date completed: 4-17-2014 , 20

7. Water Level  
Static water level: 98 feet below land surface  
Artesian Flow: 0 G.P.M. 0 P.S.I.  
Water Temperature: cold °F  
Quality: good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>35</u>	<u>2</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name: Davis Drilling and Pumps Contractor  
Address: HC 61 Box 54 Contractor  
Hiko NV 89017  
Nevada contractor's license number 0028966  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 1191  
Division of Water Resources, the on-site driller  
Signed: Mike Davis  
By driller performing actual drilling on-site or contractor  
Date: 4-17-2014