STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 12009
Permit No. 40740 & 40743
Basin No. 058

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63712
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Central Nevada Hay Company
MAILING ADDRESS 6822 Starlight Drive
Morrison, CO 80465

DETAILED ADDRESS AT WELL LOCATION Reese River Valley
Nevada
Subdivision Name: *County:* Lander

2. PLS LOCATION SW ¼ SE ¼ 23 Sec 25N N/S 42 E
PERMIT/WAIVER NO. 40740 & 40743 *Issued by Water Resources* *Current Parcel No.*

Latitude 40.17687 N UTM E ☐ NAD 27
Longitude 117.21172 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 111121
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☒ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Clay w/ Sand			500	515
Gravel		X	515	543
Clay			543	592
Rock			592	723
Brown Clay			723	747
Black Rock			747	802
Brown Rock			802	1020
Deepen well log	111121			
NAD 27				
40.01766°N				
117.21696°W				

Date started: 19-Mar , 20 14
Date completed: 4-Apr , 20 14

7. WATER QUALITIES
Static water level: 212 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
450	129	6

9. CONSTRUCTION
Depth Drilled: 1020 Feet Depth Cased: 1020 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
15	Inches	500	Feet	1020	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33.41	.250	220	780
8	22.38	.250	740	1020

ANNULAR MATERIALS

Sanitary Seal ☐ Yes X ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Mill Cut
Size of perforation: 0.25

From 220	Feet	To 1020	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Co *Contractor*
Address P.O. Box 1265 Fallon, NV 89406 *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on site driller):* 2307

Signed: *(or driller performing actual drilling on site for contractor)*
Date: 4/15/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.