STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120014
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66619
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Dick Garren
MAILING ADDRESS 1780 Amber GV NV

DETAILED ADDRESS AT WELL LOCATION 1780 Amber GV
Subdivision Name: *County:* Douglas

2. PLS LOCATION NE ¼ SE ¼ 26 Sec 13 N/S 20 E
PERMIT/WAIVER NO. Dom14-07 *Issued by Water Resources* | 1.32026E+11 *Current Parcel No.*

Latitude 38 57.501 UTM E ☐ NAD 27
Longitude 119 41.782 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 13992
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Gravel sand			150	180
clay and and sand			180	195
Gravel			195	245
clay sand			245	256
gravel			256	300
deepens well log 13992				
Nad27				
38.958442°N				
119.695359°W				
APN 1320-26-002-012				

Date started: 25-Mar , 20 14
Date completed: 28-Mar , 20 14

7. WATER QUALITIES
Static water level: 128 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality: clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
50+		2.5

9. CONSTRUCTION
Depth Drilled: ~~150~~ 300 Feet Depth Cased: 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		150 Feet	300 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	0.4	SDR 21	6	300

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	300 to	80	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory Screen
Size of perforation: 0.9

From	Feet	To	Feet
240		300	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Blain Drilling *Contractor*
Address PO 1255 CC NV 89702 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 46498A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2134
Signed: *By driller performing actual drilling on site or contractor*
Date: April 3 2014

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.