STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120054
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37634

1. OWNER Rabih Hamdan
MAILING ADDRESS 4411 N. Rancho Dr. LV. NV. 89130
ADDRESS AT WELL LOCATION NONE
Scottie + Grand Teton, LV. NV.
Subdivision Name
County Clark

2. LOCATION SE ¼ SW ¼ Sec 7 T 19 N/S R 59 E
PERMIT/WAIVER No. 126.07.401.009
Issued by Water Resources
Parcel No. 401 DSB
Latitude 36.30868
Longitud 115.416741
UTM E
☑ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented Gravel		0	195	
Hard Limestone		195	200	
Shale		200	210	
Yellow Sandstone		210	215	
Limestone		215	245	
Limestone Streaks of Shale		245	375	
Yellow		375	377	
Shale		377	490	
Limestone		490	510	
Limestone + Shale & Water		510	525	
Limestone - Very hard		525	550	
Fractured Limestone + Water		550	570	

DCNR/DWR/SNBC
RECEIVED
MAR 30 2015

Date started 3-24-14 20
Date completed 4-17-14 20

7. Water Level
Static water level: 335 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality:

8. WELL TEST DATA
TEST METHOD ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR/SNBC
RECEIVED
APR 18 2014

9. WELL CONSTRUCTION
Depth Drilled 570 Feet Depth Cased 570 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	0	Feet	570	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.9	ASCMF	SDR 17 480 PVC .65	+2	570
8 5/8	16.7	.188	+2.2	570

Perforations
Type of perforation Drilled
Size of perforation 1/4"
From 500 feet to 560 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☑ Concrete Grout 0 to 56 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type
Bentonite Chips ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Contractor
Address 13047 Horse Dr.
Contractor
Las Vegas, Nev. 89166
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick
By driller performing actual drilling on-site or contractor
Date 4-18-14

Desi,
This in the copy of the corrected log from Vern

USE ADDITIONAL SHEETS IF NECESSARY

36.3087148 ~~36.3086944~~
-115.4158969 ~~-115.415922~~
NAD 27

(NSPO 3

09/26/2014 by DSB