STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120062
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70765

1. OWNER Salvador Avalos
MAILING ADDRESS 6445 Allen Rd.
Winnemucca NV. 89445

ADDRESS AT WELL LOCATION 6445 Allen Rd.
Winnemucca NV.
Subdivision Name: County: Humboldt

2. LOCATION SW ¼ SE ¼ Sec 12 T 35 N/S R 37 E
PERMIT/WAIVER No. 35 37-12-451004
Issued by Water Resources Parcel No.

Latitude N40°55.008
Longitude W117°45.871
UTM E N
■ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
■ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Existing hole	NO	0	120	120
Existing hole	Yes	120	140	20
Coarse gravel Sand		140	240	100

deepened with air lift
Nad27
40.91600N
117.76451W

Date started: 3-30, 20 14
Date completed: 4-4, 20 14

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	140	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	Sched 40	120	240

Perforations:
Type of perforation slot
Size of perforation .02
From 120 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ■ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ■ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level 120 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	NA	3 hrs

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 4-14-14

(Rev. 05-03)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627