STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120107
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71423
WELL NAME (if applicable):

1. OWNER/CLIENT NAME ALTON ANKERS
MAILING ADDRESS P.O. BOX 995
MINDEN, NV 89423

DETAILED ADDRESS AT WELL LOCATION 671 MOTTSVILLE LANE
GARDNERVILLE, NV 89460
Subdivision Name: County: Douglas

2. PLS LOCATION ~~NW~~ SW ¼ NE ¼ 12 Sec 12 N/S 19 E
PERMIT/WAIVER NO. 1219-12-001-012
Issued by Water Resources Current Parcel No.

Latitude 38.919169*N UTM E ☐ NAD 27
Longitude 119.796043*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
COURSE DG SANDS			3	46
BROWN CLAY			46	51
LARGE GRAVELS	X		51	105
GRAY SILTY CLAY WITH SMALL GRAVELS	XX		105	148
LARGE COURSE GRAVELS 1/4	XXX		148	200

Nad 27
38.919262°N
119.795032°W

2014 MAY -7 PM 12:33
STATE ENGINEERS OFFICE

Date started: 23-Apr, 20 14
Date completed: 24-Apr, 20 14

7. WATER QUALITIES
Static water level: 0 Feet below land surface
Artesian Flow: 8 G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
50+	45	3 HRS

9. INSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	200

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	100	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	200	☐ Pumped	☐X Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: .3X3/32

From		To	
160	Feet	200	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE, CARSON CITY NV 89706
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905

Signed: Michael L Hack
By driller performing actual drilling on site or contractor
Date: 4/26/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.