

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

**OFFICE USE ONLY**  
Log No. 120134  
Permit No. \_\_\_\_\_  
Basin No. 105

**PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 71424  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME RIDGELINE DEVELOPMENT  
MAILING ADDRESS P.O. BOX 21815  
CARSON CITY, NV 89721

DETAILED ADDRESS AT WELL LOCATION 1922 WISEMAN LANE  
GARDNERVILLE, NV 89410

Subdivision Name: \_\_\_\_\_ County: Douglas

2. PLS LOCATION NW 1/4 NE 1/4 25 Sec 12 N/S 20 E  
PERMIT/WAIVER NO. 1220-25-501-021  
Issued by Water Resources Current Parcel No.

Latitude 38.880542°N UTM E  NAD 27  
Longitude 119.682398°W UTM N  NAD 83/WGS 84

3. **WORKED PERFORMED**  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. **PROPOSED USE**  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. **WELL TYPE**  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
BROWN CLAY			3	24
OBSIDIAN GRAVELS			24	136
BROWN CLAY			136	181
SMALL GRAVELS			181	220
FRACTURED GRAVELS				
SOFT SANDY CLAY ZONES	XX		220	240
FRACTURED GRAVELS	XX		240	280

9. INSTRUCTION				
Depth Drilled:	280	Feet	Depth Cased:	280
HOLE DIAMETER (BIT SIZE)				
	From	To		
11 1/4	Inches	0	Feet	280
	Inches		Feet	
	Inches		Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8	4.26	.216	20	280

ANNULAR MATERIALS				
Sanitary Seal	X	Yes	No	
<input type="checkbox"/> Neat Cement				<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Cement Grout	0		50	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout				<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Bentonite Chips				<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Gravel Pack [ > 0.2 in. ]	50		280	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Sand Pack [ < 0.2 in. ]				<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Other, explain:				<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

Date started: 23-Apr 20 14  
Date completed: 30-Apr 20 14

PERFORATIONS:				
Type of perforation:	FACTORY MILL SLOT			
Size of perforation:	0.032			
From	240	Feet	To	280
From		Feet	To	
From		Feet	To	
From		Feet	To	

7. **WATER QUALITIES**  
Static water level: 95 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: COLD ° Fahrenheit  
Water Quality: GOOD

10. **DRILLER'S CERTIFICATION**  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.  
Contractor  
Address 20 KIT KAT DRIVE, CARSON CITY, NV 89706  
Contractor

8. WELL TEST DATA			
Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>18-20</u>	<u>65</u>	<u>3 HRS</u>

Nevada contractor's license number as issued by the State Contractor's Board: 0055548  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905  
Signed: [Signature]  
By driller performing actual drilling on-site or contractor  
Date: 5/12/2014