

STATE OF NEVADA  
USE ADDITIONAL SHEETS IF NECESSARY  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY  
Log No. 120145  
Permit No. 49105  
Basin 105

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71428

WELL NAME (if applicable):

1 OWNER INDIAN HILLS GID  
MAILING ADDRESS 3394 JAMESLEE PARK  
CARSON CITY, NV 89703 14N

ADDRESS AT WELL LOCATION 3394 JAMESLEE PARK  
CARSON CITY, NV 89703  
Subdivision Name: County: Douglas

2 LOCATION SW 1/4 SW 1/4 Sec 7 T 15N N/S R 20 E  
PERMIT/WAIVER No. 48105 1419-00-002-034  
Issued by Water Resources Parcel No.

Latitude 39.08514°N UTM E NAD 27  
Longitude 119.788018°W N NAD 83/WGS 84

3 TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

Is this well being plugged because a replacement well was drilled? NO  
If yes, what is replacement well NOI?

Is there an existing well log? YES  
If yes, what is NDWR well log #? 25699

4 EXISTING WELL CONSTRUCTION  
Depth Drilled 281 Feet Depth Cased 281 Feet

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	15.24	.188	0	169
6 5/8	13.03	.188	0	281

If well was not cleaned out to total depth, please explain why:  
Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no If pulled from: \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Was the casing over drilled?  yes  no

Existing Perforations:

Type of perforation	Size of perforation	From	To
FACTORY MILL SLOT	3X3/32	55 feet	281 feet

Additional Perforations:  
Type of perforator used: NONE/ ALREADT PERFORATED

From	To	Number of perfs per linear foot
55 feet	281 feet	4

5 WATER LEVEL  
Static water level 49 feet below land surface  
Artesian flow G.P.M. P.S.I.  
Water temperature COLD °F Quality N/A

6 Additional Notes or Comments

PULLED OUT OLD 3 HP PUMP, TAGGED BOTTOM OF WELL AT 281' PLACED 3/4 OETCO HOLE ABANDONMENT 3/4 PELLETS FROM 38' TO 281'. PLACED NEAT CEMENT TO SURFACE. CUT OFF CASING AND COVERED UP.

8 WELL PLUGGING MATERIALS

From	To	Material Used	Pumped	Poured
38 feet	281 feet	BENTONITE	<input type="checkbox"/>	<input type="checkbox"/>
		HOLE PLUG	<input type="checkbox"/>	<input type="checkbox"/>
0 feet	38 feet	NEAT CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>

Neat Cement Fluid Weight 94/4 lbs/gal  
Bentonite Grout HOLE PLUG 3/4 % bentonite  
Date Started 5/20/2014  
Date Completed 5/23/2014

plug well log 25699  
39.085231°N  
119.788005°W

9 DRILLER'S CERTIFICATION  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.  
Address 20 KIT KAT DRIVE, CARSON CITY, NV 89706  
Nevada contractor's license number 0055548  
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1905  
Signed [Signature]  
Date 5/23/2014