STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120218
Permit No.
Basin No. 048

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71620
WELL NAME (*If applicable*):

1. OWNER/CLIENT NAME PAULA PRICE
MAILING ADDRESS 2620 RUBY VISTA DR
ELKO, NV 89801

DETAILED ADDRESS AT WELL LOCATION PICKERING AVE
BLK 17 LOT 8
Subdivision Name: LUCKY NUGGET RANCHES 1 *County:* ELKO

2. PLS LOCATION NE ¼ SE ¼ 15 Sec 32N N/S 55 E
PERMIT/WAIVER NO. _____ *Issued by Water Resources*
027-017-008 *Current Parcel No.*

Latitude _____ UTM E 11T 0605077 [X] NAD 27
Longitude _____ UTM N 4501053 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Monitor
[ ] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [X] Rotary [ ] RVC
Air [X] Mud [ ] Sonic
[ ] Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
TOP SOIL			0	5
SAND			5	20
GRAY CLAY & GRAVEL			20	30
GRAVEL			30	140
first water @ 40'				
Nad 27				
40.655556° N				
115.757090° W				

Date started: 9-May , 20 14
Date completed: 14-May , 20 14

9. *INSTRUCTION*
Depth Drilled: 140 Feet Depth Cased: 138 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	138

ANNULAR MATERIALS

Sanitary Seal x [X] Yes [ ] No

[X] Neat Cement	4	to	105	[X] Pumped	[ ] Poured
[ ] Cement Grout		to		[ ] Pumped	[ ] Poured
[ ] Concrete Grout		to		[ ] Pumped	[ ] Poured
[ ] Bentonite Chips		to		[ ] Pumped	[ ] Poured
[ ] Gravel Pack [> 0.2 in.]	105	to	140	[ ] Pumped	[X] Poured
[ ] Sand Pack [< 0.2 in.]		to		[ ] Pumped	[ ] Poured
[ ] Other, explain:		to		[ ] Pumped	[ ] Poured

PERFORATIONS:
Type of perforation: PLASMA CUT
Size of perforation: 3/16" X 4", 7 ROW

From	Feet	To	Feet
118	Feet	138	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. *WATER QUALITIES*
Static water level: 30 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
135'	25		2
115'	25		.5
100'	20		10 MINUTES
80	16		10 MINUTES

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name HACKWORTH DRILLING INC. Contractor
Address P.O. BOX 850, ELKO, NV 89803 Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 020582
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 4166
Signed: Dale C. Vedan *By driller performing actual drilling on site or contractor*
Date: 5/15/2014

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.