STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120235
Permit No. 80757
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70894

1. OWNER Robin Fryling / Scott Kotton
MAILING ADDRESS P.O. Box 174
Golconda NV. 89414

ADDRESS AT WELL LOCATION 10200 Conservation Rd.
Winnemucca NV.
Subdivision Name: County: Humboldt

2. LOCATION NW ¼ SW ¼ Sec 23 T 35 N/S R 36 E
PERMIT/WAIVER No. 80757 (Issued by Water Resources) 3536-23-300-001 (Parcel No.)

Latitude N 40°53.646
Longitude W 117°54.372
UTM E
N
■ NAD 27
☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
■ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay, sand	NO	0	10	10
cobbles-clay, sand	NO	10	100	90
cemented gravel, clay	yes	100	200	100

Lat 27
40.894100N
117.906200W

Date started: 5-6- , 20 14
Date completed: 5-9 , 20 14

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16 5/8	Steel	.188	0	20
16 5/8	PVC	Sched 40	20	200

Perforations:
Type of perforation slot
Size of perforation .20
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 20 ☐ Pumped ■ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ■ No 100 to 200 ☐ Pumped ■ Poured
Type: 3/8" Pea
Bentonite Chips: ■ Yes ☐ No 20 to 100 ☐ Pumped ■ Poured
Type: 3/8" chip

7. Water Level
Static water level: 82 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	NA	4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 5-15-14

RECEIVED JUN 2 2014 DIVISION OF WATER RESOURCES

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-05)