STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120242
Permit No.
Basin No. 137A

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37212
WELL NAME *(if applicable)*: mw-d

1. OWNER/CLIENT NAME Tonopah Resources Inc.
MAILING ADDRESS 611 Walnut STGadsden Al 35901

DETAILED ADDRESS AT WELL LOCATION General County(Miller mill)
Subdivision Name: *County:* Esmeralda

2. PLS LOCATION SE ¼ NW ¼ 11 Sec 03N N/S 40e E
PERMIT/WAIVER NO. nev2013#106 *(issued by Water Resources)* 006-111-08 *(Current Parcel No.)*

Latitude 38.133425 UTM E
Longitude 117.455761 UTM N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☒ Other HAS

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
sand			0	10
gravel sand			10	50
gravel clay and sand			50	51
gravel sand			52	80

Nad 27
38.133444°N
117.454835°W

DCNR/DWR/SNBO
RECEIVED
JUN 03 2014

Date started: 12-May , 20 14
Date completed: 13-May , 20 14

9. CONSTRUCTION
Depth Drilled: 80 Feet Depth Cased: 80 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8"	Inches	0	Feet	80	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	SCH 40	+3	80

ANNULAR MATERIALS
Sanitary Seal YES☐ ☐ No

☐ Neat Cement	x	to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	20	☐ Pumped	☒ Poured
☒ Concrete Grout	20	to	52	☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	52	to	80	☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: MACHINE
Size of perforation: 0.02

From	Feet	To	Feet
55	Feet	75	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 54 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Eagle Drilling Services *(Contractor)*
Address 7150 Placid Las Vegas NV 89119 *(Contractor)*
Nevada contractor's license number as issued by the *State Contractor's Board* 51266
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)* Timothy Thompson 2097
Signed: *(By driller performing actual drilling on site or contractor)*
Date: 5/27/2014

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.

2014 JUN -9 AM 10:23 ENGINEERING OFFICE