STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 120259
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37774
WELL NAME (if applicable): MW-9A

1 OWNER Behrooz Faridian
MAILING ADDRESS 1521 Livonia Ave
Los Angeles, CA 90035

ADDRESS AT WELL LOCATION 2450 E. Bonanza RD
Las Vegas, NV
Subdivision Name: County: Clark

2 LOCATION NE ¼ NE ¼ Sec 35 T 20S N/S R 61 E
PERMIT/WAIVER No. 139-35-501-002
Issued by Water Resources Parcel No.

Latitude 36°10'25.56"N
Longitude -115°6'59.31"W
UTM E
N
☒ NAD 27
☐ NAD 83/WGS 8

3 TYPE OF WELL
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NO!?

Is there an existing well log? NO
If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	0.68	0.154	0	30

Existing Perforations:
Type of perforation Factory
Size of perforation 0.02

From	feet to	feet
10	30	feet
		feet
		feet
		feet
		feet

5 WATER LEVEL
Static water level 15.5 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

6 Additional Notes or Comments

DCNR/DWR/SNPO
RECEIVED
JUN 4 2014

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? ☒ yes ☐ no
If well was not cleaned out to total depth, please explain why:

Was the well contaminated? ☐ yes ☒ no
Was the casing pulled? ☒ yes ☐ no If pulled from: 0 feet to ~~35~~ 30 feet
Was the casing over drilled? ☐ yes ☒ no
If casing was left in place, please show where additional perforations were made:

Additional Perforations:
Type of perforater used: NA

From	feet to	feet	Number of perfs per linear foot

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used		
0	.50		Asphalt	☐ Pumped	☒ Poured
0.5	1		Class II Base	☐ Pumped	☒ Poured
1	30		Bent.Cement	☒ Pumped	☐ Poured
				☐ Pumped	☐ Poured
				☐ Pumped	☐ Poured
				☐ Pumped	☐ Poured

Neat Cement Fluid Weight 5.2 lbs/gal
Bentonite Grout 3 % bentonite

Date Started 5/14/2014
Date Completed 5/14/2014

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name National EWP
Contractor
Address 5241 Schrills Street, Las Vegas, NV 89118
Contractor

Nevada contractor's license number issued by the State Contractor's Board 00735355
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111-T1
Signed Bob
By driller performing actual drilling on site or contractor
Date 5/29/2014

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.

36.1737957
-115.1156413
NAD 27