STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 12031
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71429
WELL NAME (if applicable):

1. OWNER/CLIENT NAME: CUSTOM SERVICES BY SILVERIA
MAILING ADDRESS: 2447 MT COMO RD
GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION: 2005 GRAY COURT
GARDNERVILLE, NV 89410
Subdivision Name: County: Douglas

2. PLS LOCATION SW ¼ NE ¼ 1 Sec 12 N/S 20 E
PERMIT/WAIVER NO. 1220-01-001-065
Issued by Water Resources Current Parcel No.

Latitude 38.935344*N UTM E ☐ NAD 27
Longitude 119.686502*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	4
COURSE OBSIDIAN GRAVELS			4	28
LARGE GRAVELS			28	63
COURSE DG GRAVELS			63	148
BROWN CLAY			148	163
OBSIDIAN SANDS AND GRAVELS WITH CLAY SEAMS	XXX		163	260

Nad 27
38.935436 N
119.685495

Date started: 16-Jun, 20 14
Date completed: 18-Jun, 20 14

9. INSTRUCTION
Depth Drilled: 260 Feet Depth Cased: 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8	4.26	.216	20	260
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	65	☐ Pumped	☐ X Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	65	to	260	☐ Pumped	☐ X Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: 3X 3/32

From	220	Feet	To	260	Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet

7. WATER QUALITIES
Static water level: 95 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	70	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address: 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0065548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905

Signed: Michael Hack
Driller performing actual drilling on site or contractor
Date: 6/18/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.