STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120331
Permit No. 78185 78186
Basin 179

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70657

1. OWNER Quadra-Robinson NV Mining AGT-9PR
MAILING ADDRESS P.O Box 382
Ruth, NV. 89319

ADDRESS AT WELL LOCATION Robinson Mine, 2 Miles South of Ruth NV.
Subdivision Name: County: White Pine

2. LOCATION SW¼SE¼ Sec11T16N/ R62E
PERMIT/WAIVER NO. ORDER# 1198 (Issued by Water Resources) Parcel. No.

Latitude
Longitude
UTM E 676062 ☒ NAD 27
N 4347523 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Conventional

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dump Fill		0	250	250
Welded ring to production and surface pipe.				

Nad 27
39.2464056 N
114.9593375 W

Date started: May 4, 20 14
Date completed: May 12, 20 14

7. Water Level
Static water level: 12 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Warm °F
Quality: Poor

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
90	4	3

9. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
20 Inches	0 Feet	50 Feet
12.25 Inches	50 Feet	250 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.712	.250	0	50
6.625	17.02	.250	+2	250

Perforations:
Type of perforation Full Flo Louvered
Size of perforation .08
From 10 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 0 to 250 ☐ Pumped ☒ Poured
Type: 1/2" X 1/4" SRI Supreme
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2486
Signed
By driller performing actual drilling on site or contractor
Date May 15, 2014

2014 MAY 19 AM 10:36
WATER RESOURCES

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com