STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120378
Permit No.
Basin No. 089

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71597
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Travis & Heidi Kieckbush
MAILING ADDRESS 9310 Ogden Trail Drive
Sparks,Nv 89441

DETAILED ADDRESS AT WELL LOCATION 5605 Pony Springs Road
Reno,Nv 89510
Subdivision Name Palomino Valley Unit 1 County: Washoe

2. PLS LOCATION SW ¼ NW ¼ 27 Sec 22 N 21 E
PERMIT/WAIVER NO. 077-170-13
Issued by Water Resources Current Parcel No.

Latitude 39.74608 UTM E ☐ NAD 27
Longitude -119.61734 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 42921
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
DG		x	218	410
Total depth 410 feet				
Deepen well log#42921				
NAD 27				
39.746171°N				
119.616323°W				

Date started: 23-Jun , 20 14
Date completed: 25-Jun , 20 14

9. INSTRUCTION
Depth Drilled: 410 Feet Depth Cased: 410 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6-1/8	Inches	218	Feet	410	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5-9/16	10.7	.188	210	410

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: In Place to ☐ Pumped ☐ Poured

PERFORATIONS
Type of perforation: Mill Slot
Size of perforation: 3/32 x 3

From	Feet	To	Feet
230	Feet	250	Feet
270	Feet	290	Feet
330	Feet	350	Feet
390	Feet	410	Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 150 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30	175	.5
40	200	.5
80	250	.5
100	300	1.
100+	400	1.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Domestic Pump & Supply
Contractor
Address P.O. Box 60130 Reno,Nv 89506
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0035387D
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2121
Signed: Larry Welch
(to under performing actual drilling on site or contractor)
Date 6/26/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.