

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120499 120499
Permit No. _____
Basin 064

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70621

1. OWNER Mr Johnson
MAILING ADDRESS Box 2435
Grader V. 119 NV 89410
2. LOCATION NE 1/4 NE 1/4 Sec 10 T 32 N/S R 44 E
PERMIT/WAIVER No. 14-23 10-270-06

ADDRESS AT WELL LOCATION 2210 ALLEN Rd
BATTLE MTN NV 89820
Subdivision Name: _____
County: LANDON
Latitude UTM E 500187 NAD 27
Longitude N 4501507 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	5	
SAND		5	10	
PRA GRAVEL		10	35	
Grey CLAY		35	45	
GREEN CLAY		45	80	
YELLOW CLAY		80	95	
Yellow clay + SAND		95	120	

7. Water Level
Static water level: 75 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: Cold °F
Quality: Good

9. WELL CONSTRUCTION

Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 5/8</u>	<u>D</u>	<u>120</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.189</u>	<u>+1</u>	<u>120</u>

Perforations:

Type of perforation SAWED
Size of perforation 3/16 x 3

From	feet to	feet	feet
<u>100</u>	<u>120</u>		

Annular Seal: Yes No

Material	to	to	Pumped	Poured
<input type="checkbox"/> Neat Cement			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout	<u>5</u>	<u>3.5</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> 80% Bentonite Grout			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack: Yes No 90 to 120 Pumped Poured
Type: 3/16

Bentonite Chips: Yes No 35 to 90 Pumped Poured
Type: 3/16

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>Unit</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LBJ DRILLING & PUMP COMPANY, INC.
Contractor

Address P.O. BOX 902 - Winnemucca, NV 89446
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0009605A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807

Signed Joe Boggio
By driller performing actual drilling on site or contractor: Joe Boggio

Date _____