STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 120505
Permit No.
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68204

1. OWNER Daryle G. Moore
MAILING ADDRESS Box 151086
Ely Nv. 89315

ADDRESS AT WELL LOCATION 7625 North Blue Bird Dr.
Bird creek
Subdivision Name: —— County: White Pine

2. LOCATION NE ¼ SW ¼ Sec 32 T 19 N S R 65 E
PERMIT/WAIVER No. —— 010-840-1
Issued by Water Resources Parcel No.

Latitude N 39° 28.167'
Longitude W 114° 41.298'
~~UTM~~ Elev. 6831 ☐ NAD 27
N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sand Stone		3	30	27
Altered Volcanics		30	60	30
Sand Stone Rubble		60	80	20
Altered Volcanics		80	100	20
Fractured Volcanics	X	100	120	20
Volcanics		120	130	10
Fractured Volcanics	X	130	140	10
Redish Volcanics		140	170	30
Volcanics with clay stringers		170	180	10
Volcanics		180	235	55
Fractured Volcanics	X	235	245	10
Redish Volcanics		245	260	15

Nad 27
39.469511°N
114.687452°W

Date started: 7-2, 20 14
Date completed: 7-8, 20 14

9. WELL CONSTRUCTION
Depth Drilled 260' Feet Depth Cased 260' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11¼'	Inches	0	Feet	260'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝"	12.92	.188	+2'	20'
6.625	4.95	SDR-17	20'	260'

Perforations:
Type of perforation Slotted
Size of perforation .030
From 160' feet to 260' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 5' to 55' ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 55' to 260' ☐ Pumped ☒ Poured
Type: 3/8" Pea gravel Washed
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type: ——

7. Water Level
Static water level: 88' feet below land surface
Artesian Flow: — G.P.M. — P.S.I.
Water Temperature: 54 °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	40	172'	3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name David Gibson Contractor LLC
Contractor
Address P.O. Box 203 Lund Nv. 89317
Contractor
D.B.A. Gibson Well Drilling
Nevada contractor's license number issued by the State Contractor's Board 0077887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793 / 2315
Signed [signature] Dennis H. Eldridge
By driller performing actual drilling on-site or contractor
Date 7-15-14

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627