Well # 2

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 1205R
Permit No.
Basin 064

NOTICE OF INTENT NO. 72086

1. OWNER Todd Price
MAILING ADDRESS P.O. Box 1522
Battle Mtn 89820

ADDRESS AT WELL LOCATION 415-26th ST.
Battle Mtn NV 89820
Subdivision Name: County: Lander

2. LOCATION SW ¼ SW ¼ Sec 24 T 32 N/S R 44 E
PERMIT/WAIVER No. 14-25 111-050-43
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 502179 ☒ NAD 27
N 4497076 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	
Sand		5	15	
Gray Shale		15	25	
Yellow Clay		25	40	
Green Clay		40	85	
Yellow Clay		85	90	
Sandy Yellow Clay		90	95	
Shale		95	100	
Pea Gravel		100	110	
Sandy Yellow Clay		110	120	
Nad27				
40.626415N				
116.474236W				

Date started: 7-18, 20 14
Date completed: 7-19, 20 14

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation Sawed
Size of perforation 3/16 x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout 5 to 60 ☐ Pumped ☐ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 90 to 120 ☐ Pumped ☒ Poured
Type: 3/8"
Bentonite Chips: ☒ Yes ☐ No 60 to 90 ☐ Pumped ☒ Poured
Type: 3/8"

7. Water Level
Static water level: 45 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	100+	UNK	1 Hr.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC. (Contractor)
Address P.O. BOX 902 - Winnemucca, NV 89446 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0009605A
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1807
Signed Joe Boggio (By driller performing actual drilling on site or contractor)
Date Joe Boggio

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY